

产品认证证书

II型自愿认证

证书编号：CQC2019010307266418

发证日期：2022年01月19日

有效期至：2032年01月19日

委托人名称	人民电器集团有限公司
及注册地址	浙江省乐清市经济开发区(柳市人民工业园)
制造商名称	人民电器集团有限公司
及注册地址	浙江省乐清市经济开发区(柳市人民工业园)
生产企业名称	浙江人民电器有限公司
及生产地址	浙江省乐清市柳市镇柳乐路 555 号
产品名称和系列、规格、型号	剩余电流动作断路器 RDM32LE-320□□/W ; Ue : AC400V ; Ui : 1000V ; Uimp : 8kV ; In : 250A (100A~250A 无级可调)、320A (128A~320A 无级可调) ; 过电流脱扣器 类型 : 电子式 ; I Δ n : 50mA、100mA、150mA、200mA、300mA、500mA、800mA、1000mA 分级可调/AC 型 ; 剩余电流脱扣器类型 : 电子式 ; RDM32LE-320Y/W : Ics : 25kA ; Icu : 35kA ; RDM32LE-320YM/W : Ics : 35kA ; Icu : 50kA ; Icw : 4kA/1s ; 选择性类别 : A 类 ; I Δ m : 25% Icu ; 自 动重合闸时间 : 20s ~ 60s ; 极数 : 3P+N (三个保护极 , 带不可开断中性线 , 不适用于隔离用)
产品标准和技术要求	GB/T 14048.2-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求，特发此证。

本证书为变更证书，证书首次颁发日期：2020年05月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

杨志刚

谢肇煦



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2019010307266418

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

3.3 型号的解释:

<u>RD</u>	<u>M</u>	<u>32</u>	<u>LE-</u>	<u>320</u>	<u>□</u>	<u>□</u>	/	<u>W</u>
(1)	(2)	(3)	(4)	(5)	(6)	(7)		(8)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计序号:32
- (4) 带剩余电流动作保护功能
- (5) 壳架等级额定电流(A): 320
- (6) 显示方式: Y-液晶
- (7) 分断能力: 无代号;表示低分断; M: 表示高分断
- (8) 功能代号: W-物联网



中国质量认证中心

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010307266418

Valid from: Jan.19,2022

Valid until: Jan.19,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT People Electrical Appliances Group Co.,Ltd.
(People Industry Zone, Liushi)Economic Development Zone, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER People Electrical Appliances Group Co.,Ltd.
(People Industry Zone, Liushi)Economic Development Zone, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY Zhejiang People Electric Appliance Co., Ltd.
No.555 Liule Road, Liushi Town, Yueqing City, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION RESIDUAL CURRENT OPERATED CIRCUIT-BREAKER
RDM32LE-320□□/W; Ue: AC400V; Ui: 1000V; Uimp: 8kV; In: 250A (100A~250A 无级可调)、320A (128A~320A 无级可调); 过电流脱扣器 类型: 电子式; I_{Δn}: 50mA、100mA、150mA、200mA、300mA、500mA、800mA、1000mA 分级可调/AC 型; 剩余电流脱扣器类型: 电子式; RDM32LE-320Y/W: Ics: 25kA; Icu: 35kA; RDM32LE-320YM/W: Ics: 35kA; Icu: 50kA; Icw: 4kA/1s; 选择性类别: A 类; I_{Δm}: 25% Icu; 自 动重合闸时间: 20s~60s; 极数: 3P+N (三个保护极, 带不可开断中性线, 不适用于隔离用)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.2-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: May.14,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

杨志刚

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO. : CQC2019010307266418

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

3.3 型号的解释:

RD M 32 LE - 320 □ □ / W
(1) (2) (3) (4) (5) (6) (7) (8)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计序号:32
- (4) 带剩余电流动作保护功能
- (5) 壳架等级额定电流(A): 320
- (6) 显示方式: Y-液晶
- (7) 分断能力: 无代号;表示低分断; M: 表示高分断
- (8) 功能代号: W-物联网



CHINA QUALITY CERTIFICATION CENTRE